



Sangre De Cristo Laboratory, Inc.

Tierra Del Sol Industrial Park
2329 Lava Lane
P.O. Box 642
Alamosa, CO 81101

(719) 589-1024

DATE COLLECTED: 04/07/08
SYSTEM NAME: VALLEY VIEW HOT SPRINGS
MAILING ADDRESS: P. O. BOX 65, VILLA GROVE, CO 81155
TIME COLLECTED: 10:10 AM **COUNTY:** SAGUACHE
CONTACT PERSON: T. SEITZ **TEL. NUMBER:** 719-256-5212
COLLECTED BY: NS **WATER TYPE:** NON-COMMUNITY
SAMPLE LOCATION: SOURCE

LABORATORY INFORMATION:

LAB SAMPLE NO: 27917-27918
DATE RECEIVED: 04/07/08 **REPORT DATE:** 04/10/08

PARAMETER	(mg/L) RESULTS	(mg/L) MCL	(mg/L) LAB MDL	METHOD
ALKALINITY	90.7	**	1.0	2320B
CALCIUM	45.100	**	1.0	10520001B
IRON	0.045	**	0.024	3111B
MAGNESIUM	10.8	**	0.5	10520001B
MANGANESE	ND	**	0.015	3111B
pH	5.52	**	1 - 14	150.1
TDS	250	**	1.0	160.1
TOTAL HARDNESS	157.1 HARD	**	1.0	2320A
TOTAL SUSPENDED SOLIDS	<1.0	**	1.0	2540D

** Does not have a MCL
 mg/L = Milligrams per liter
 MCL = Maximum Contaminant Level
 ND= Not detectable at laboratory's MDL
 Lab MDL = Laboratory Method Detection Limit

Reviewed & Approved by:

Ronny Gossard

Date:

4/10/08

COLORADO DEPARTMENT OF HEALTH
INORGANIC CHEMISTRY LABORATORY
4210 E 11TH AVE. DENVER, CO 80220
(303)691-4726

DATE: 05/22/96
REPORTED BY: SA

SAMPLE NUMBER: 961224
SAMPLE DESCRIPTION: VALLEY VIEW HOT SPRINGS

PWSID #:

ADDRESS : PO BOX 175
VILLA GROVE, CO 81155

COUNTY:
PHONE : 7192564315

COLLECTED BY: TS
WHERE: MIDDLE SPRING
DATE SAMPLED: 04/15/96
DATE RECEIVED: 04/16/96
BOTTLES: RAD, HG, LM, L NEUT
TYPE: 8
COMMENTS: FEE PAID \$283.00

ANALYSIS RESULTS

EPA LIMITS

ALKALINITY TOT	100	mg/L	NLE	
ALPHA	5	pCi/L	MCL=15	pCi/L
BETA	< 8	pCi/L	MCL=50	pCi/L
ARSENIC	NONE DETECTED		MCL=0.05	mg/L
BARIUM	0.050	mg/L	MCL=1.0	mg/L
CADMIUM	< 0.00025	mg/L	MCL=0.005	mg/L
CALCIUM ***	120	mg/L	NLE	
CHLORIDE	< 1	mg/L	MSL=250	mg/L
CHROMIUM	< 0.010	mg/L	MCL=0.1	mg/L
COPPER	< 0.004	mg/L	EAL=1.3	mg/L
FLUORIDE	0.38	mg/L	MCL=4.0	mg/L
HARDNESS, TOT. ***	170	mg/L	NLE	
IRON	< 0.010	mg/L	MSL=0.3	mg/L
LEAD	NONE DETECTED		EAL=0.015	mg/L
MAGNESIUM	12	mg/L	MSL=125	mg/L
MANGANESE	< 0.004	mg/L	MSL=0.05	mg/L
MERCURY	NONE DETECTED		MCL=0.002	mg/L
MOLYBDENUM	< 0.010	mg/L	NLE	
PH	8.0 H			
SELENIUM	NONE DETECTED		MCL=0.05	mg/L
SILVER	< 0.002	mg/L	MCL=0.05	mg/L
SODIUM	3.1	mg/L	MSL=20	mg/L
SOLIDS, DIS.	250	mg/L	MSL=500	mg/L
SOLIDS, TOT.	360	mg/L		
SULFATE	91	mg/L	NLE	
ZINC	< 0.008	mg/L	MSL=5.0	mg/L

MCL = MAXIMUM CONTAMINANT LEVEL
MSL = MAXIMUM SUGGESTED LEVEL
NLE = NO LIMITS ESTABLISHED
EAL = EPA ACTION LEVEL
*** AS CaCO3